

# Display energy certificate (DEC)



HM Government

NIA  
Northern Ireland Assembly  
Parliament Buildings,  
BELFAST  
BT4 3SY

Operational rating

**D**

Certificate number: 2366-2612-7162-1209-4502

Valid until: 12 January 2023

Total useful floor area: 23748 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO<sub>2</sub>) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	<b>A</b>		
26-50	<b>B</b>		
51-75	<b>C</b>		
76-100	<b>D</b>	<b>80   D</b>	
101-125	<b>E</b>		100
126-150	<b>F</b>		
150+	<b>G</b>		

## This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m <sup>2</sup> /year)	76.08	101.24
Typical energy use (kWh/m <sup>2</sup> /year)	95	125.41
Energy from renewables	0%	0%

## Previous operational ratings

Date	Operational rating
January 2022	<b>80   D</b>
January 2021	<b>85   D</b>
January 2020	<b>86   D</b>

## Total carbon dioxide (CO<sub>2</sub>) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.

Date	Electricity	Heating	Renewables
January 2022	994	466	0
January 2021	1040	515	18
January 2020	1071	481	17

## Assessment details

Assessor's name	David McIntyre
Employer/Trading name	Department of Finance and Personnel
Employer/Trading address	Energy Unit EU, Clare House, BT3 9ED
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	Stroma Certification Ltd
Issue date	7 January 2022
Nominated date	13 January 2022

