

NIA
Northern Ireland Assembly
Parliament Buildings,
BELFAST
BT4 3SY

Operational rating

D

Certificate number:0991-2220-5197-7618-7664

Valid until:12 January 2024


Total useful floor area:23748 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO2) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.



This building's energy use		
Energy use	Electricity	Other fuels
Annual energy use (kWh/m2/year)	81.53	107.66
Typical energy use (kWh/m2/year)	95	116.44
Energy from renewables	0%	0%

Previous operational ratings	
Date	Operational rating
January 2023	88 D
January 2022	80 D
January 2021	85 D

Total carbon dioxide (CO2) emissions			
This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO2.			
Date	Electricity	Heating	Renewables
January 2023	1065	496	0
January 2022	994	466	0
January 2021	1040	515	18

Assessment details	
Assessor's name	David McIntyre
Employer/Trading name	Department of Finance and Personnel
Employer/Trading address	Energy Unit EU, Clare House, BT3 9ED
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	Stroma Certification Ltd
Issue date	16 January 2023
Nominated date	13 January 2023