

Display energy certificate (DEC)



NIA
Northern Ireland Assembly
Parliament Buildings,
BELFAST
BT4 3SY

Operational rating

D

Certificate number: 1242-3619-1602-0999-7506

Valid until: 12 January 2022

Total useful floor area: 23748 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D	85 D	
			100 --
101-125	E		
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
January 2021	85 D
January 2020	86 D
January 2019	88 D

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
January 2021	1040	515	18
January 2020	1071	481	17
January 2019	1086	545	18

Assessment details

Assessor's name	David McIntyre
Accreditation scheme	Stroma Certification Ltd
Employer/Trading name	Department of Finance and Personnel
Employer/Trading address	Energy Unit EU, Clare House, BT3 9ED
Issue date	13 January 2021
Nominated date	13 January 2021
Assessor's declaration	Contractor to the occupier for EPBD services only.

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	79.61	111.82
Typical energy use (kWh/m ² /year)	95	126.03
Energy from renewables	1.7%	0%