



Display energy certificate (DEC)

Northern Ireland Assembly
Parliament Buildings
Stormont Estate
BELFAST
BT4 3XX

Operational rating
D

Certificate number: 1049-6115-3732-8576-9202

Valid until: 29 June 2026


Total useful floor area: 23,911.99 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO2) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.



Previous operational ratings

Date	Operational rating
June 2025	85 D

Total carbon dioxide (CO2) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO2.

Date	Electricity	Heating	Renewables
June 2025	1,100	433	6

Assessment details

Assessor's name	Campbell Morris
Employer/Trading name	MEA Ltd
Employer/Trading address	Suite 1, Eilidh Haus, 497 Antrim Road, BELFAST, BT15 3BP
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	Kaizen Certification Ltd
Issue date	18 November 2025
Nominated date	30 June 2025

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	83.66	93.26
Typical energy use (kWh/m ² /year)	95	120.05
Energy from renewables	0.6%	0.0%

